

# Certificate of Compliance

**Certificate:** 1278780

**Master Contract:** 200408

**Project:** 1278780 (Edition 1)

**Date Issued:** February 13, 2002

**Issued to:** Innova Electronics  
9207 Emmott Rd., Suite 105  
Houston, TX 77040  
USA

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



**Issued by:** William (Bill) Giesbrecht, C.E.T.  
Certification Specialist

**Authorized by:** John Verwey, P.Eng.  
Operation Manager

## PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations  
CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I, Div 2, Groups A, B, C and D: Temperature code T4:

STS 4218 & STS 4218A LCD Monitor rated 12V dc, 5A max (panel mount).

## APPLICABLE REQUIREMENTS

CSA Std C22.2 No	142-M1987	-	Process Control Equipment
CSA Std C22.2 No	213-M1987	-	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
UL Std No	746C	-	Polymeric Materials - Use in Electrical Equipment Evaluations
UL Std No	1604	-	Electrical Equipment for Use in Class I and II, Division 2; Class III Hazardous (Classified) Locations
UL Std No	508	-	Industrial Control Panels

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.



CSA INTERNATIONAL

## *Supplement to Certificate of Compliance*

**Certificate:** 1278780

**Master Contract:** 200408

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1278780	February 13, 2002	Supercedes Report LR 114237-4 to transfer report for STS 4218 LCD Monitor to this file and to update report to allow alternate construction. Change of LCD from NEC to LG.